

COUNTY OF SUFFOLK



STEVE LEVY
SUFFOLK COUNTY EXECUTIVE

DEPARTMENT OF PUBLIC WORKS

GILBERT ANDERSON, P.E.
COMMISSIONER

JAMES PETERMAN, P.E.
ACTING CHIEF DEPUTY COMMISSIONER

November 29, 2011

RE: S.C.S.D Nos. 13, 15 & 28
Wastewater Treatment Plant Improvements
CP. No. 8103

To Whom It May Concern:

This letter is for clarification of Alternate #3 in the Lump Sum Contract Bid Form. This alternate is to include the following:

- 1) Furnish and install the sludge withdrawal lines the entire distance from within the sludge tanks out to the Tanker Fill Basin. This includes the pinch valves inside the plant and the entire Tanker Fill Basin structure and push button station and any incidentals required for entire installation of the withdrawal system.
- 2) Furnish and install the utility poles with the lights. (Camera not included in contract)
- 3) Furnish and supply all electrical conduit and connections for entire operation of the sludge withdrawal lines and utility pole lights. Provide the conduit and a drag line for the CCTV cable.

Please call me at (631) 852-4189 if you have any questions.

Sincerely,

John C. Berchtold, P.E.
Division of Sanitation

Jb

SUFFOLK COUNTY IS AN EQUAL OPPORTUNITY / AFFIRMATIVE ACTION EMPLOYER